

1 10A NCAC 13S .0210 is proposed for adoption under temporary procedures as follows:

2
3 **10A NCAC 13S .0210 CORRIDORS**

4 The width of patient use corridors shall be no less than 60 inches.

5
6 *History Note: Authority 131E-153; 131E-153.5; 143B-165.*